

Certificate of Constancy of Performance

1029 – CPR – CN21/40030

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Thermal insulation products for building equipment and industrial installations - Factory made polyethylene foam (PEF) products, described in annex.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 14313:2009+A1:2013

under system 1 for the performance set out in this certificate, are applied and that

the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product

This certificate is valid from 16/12/2021 until 15/12/2024, and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Re certification audit due before 15/10/2024.

Issue 1. Certified with SGS since 16/12/2021

Authorised by

Luis Neves
Certification Management

IPAC
acreditação

C0001
ISO/IEC 17065
Produtos

SGS ICS – Serviços Internacionais de Certificação, Lda Notified Body 1029

Polo Tecnológico de Lisboa, Rua Cesina Adães Bermudes, lote 11, nº 1, 1600-604 Lisboa – Portugal
T: +351 217104200; F: +351 217157527
e-mail pt.info@sgs.com www.sgs.pt

Page 1 of 2



Certificate of Constancy of Performance
1029 – CPR – CN21/40030

Annex 1

Product(s): Thermal insulation products for building equipment and industrial installations - Factory made polyethylene foam (PEF) products.

Product description	PE Insulation Tube
Reaction to fire	BL-s1,d0
Thickness (mm)	≤25
Diameter (mm)	6-300
Use	Thermal insulation for building equipment and industrial installations